


TIGHTEN BOLT LONG BOLT TO
YOKE WITH PROVIDED NUT.

NUT AND WASHER TO HOLD FIXTURE (INCLUDED)

DETAIL A
SCALE 1 : 4

INSTRUCTIONS: --> NOTE: FOR ADDITIONAL INFORMATION, REFER TO IIS00035 <--

1. PROVIDE CEILING CUT-OUT AT 24-3/8" x 48-3/8" (2x4), 12-3/8" x 48-3/8" (1x4)
2. PROVIDE APPROPRIATE BEAM STRUCTURE TO SUPPORT FIXTURE.
3. INSTALL YOKES CENTRED IN OPENING, 38" APART. (CENTRE-CENTRE OF BOLTS.
4. ADJUST BRACKETS SO INSIDE CEILING SURFACE TO INSIDE EDGE IS APPROX 6.5". AFTER ADJUSTMENTS ARE MADE ON FIRST UNIT, REPEAT PROCESS FOR REMAINING FIXTURES.
5. INSTALL FIXTURE INTO OPENING, INSERTING BOLTS IN FOUR HOLES ON TOP OF FIXTURE. FASTEN IN PLACE WITH PROVIDED NUT AND WASHERS (4 EA PER UNIT). TIGHTEN UNTIL FIXTURE IS TIGHT TO CEILING SURFACE.
6. REPLACE FIXTURE COVERS AND CLOSE UP THE DOOR.
7. IT MAY BE USEFUL TO REMOVE THE DOOR FROM THE CABLE FOR THIS PROCESS AND RE-ATTACH AFTER IT IS COMPLETE.

	NAME	DATE	 <div>CERTOLUX SPECIALTY LUMINAIRES 35 Oak St., Toronto, ON M9N 1A1 647-777-3300</div>	
Drawn	R			
Last Saved	rdoucet	4/9/2015		
Checked				
<p>UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES ANGULAR: BEND ±1 ONE PLACE DECIMAL ±0.030 TWO PLACE DECIMAL ±0.015 THREE PLACE DECIMAL ±0.005</p>			ERP #:	IIS00114
			REVISION: 01 01	
			Title	
			Part Name: IIS-VRF3553-YOKE	
			Description: 3553 VRF WITH YOKE INSTALLATION INSTRUCTION	
			MATERIAL:	FINISH: NONE
			SIZE: A	SCALE:
			SHEET 1 of 1	

UNLESS OTHERWISE SPECIFIED:
 DIMENSIONS ARE IN INCHES
 ANGULAR: BEND ±1
 ONE PLACE DECIMAL ±0.030
 TWO PLACE DECIMAL ±0.015
 THREE PLACE DECIMAL ±0.005